



AIR FILTER TESTING LABORATORIES, INC.

4632 Old LaGrange Road • Buckner, Kentucky 40010

Phone (502) 222-5720 • Fax (502) 222-9881

REPORT NO.
14170

TEST NO.
1

SHEET NO.
1

ASHRAE STANDARD 52.2-2012 REMOVAL EFFICIENCY BY PARTICLE SIZE (0.3 to 10.0 µm; KCI)

DEVICE TESTED

Test Requested By	JANFORD AIR FLOW CO., LTD.
Manufacturer	JANFORD AIR FLOW CO., LTD.
Test Sample Procurement	FURNISHED BY MANUFACTURER
Product Name	ALUMINUM PANEL FILTER
Brand Name	
Model No.	
Dimensions	610 mm H X 610 mm W X 25 mm D (NOMINAL)

DEVICE DESCRIPTION


Generic Device Classification / Type	PANEL FILTER	
Number Of Pleats / Pockets	N/A	no.
Number Of Banks	N/A	no.
Face Dimension (Nom. Height)	610	mm H
Face Dimension (Nom. Width)	610	mm W
Depth Dimension (Nom. Depth)	25	mm D
Media Area (Net Effective)	0.37	m ²
Type Of Media	ALUMINUM	
Type And Amount Of Adhesive	NONE	
Product Description		

TEST CONDITIONS

Test Airflow Rate	3346	m ³ /hr
Test Aerosol Type	KCI	
Test Dust Type	ASHRAE	
Test Dust Feed Rate	71.0	mg/m ³
Device Test Section Duct Size	610 x 610	mm
Final Device Resistance	250	Pa
Air Temperature	23.0	°C
Relative Humidity	50	%
Optical / Aerodynamic Particle Counter(s); OPC / APC	CLIMET INST. / CI-500 (laser)	
Notes		

TEST RESULTS - see attached performance curves

Initial Device Resistance	33	Pa		
Final Device Resistance	250	Pa		
Composite Average Minimum Efficiencies	E1 (0.3 - 1.0 µm)	E2 (1.0 - 3.0 µm)	E3 (3.0 - 10.0 µm)	%
	4	9	32	
Minimum Efficiency Reporting Value (MERV)	MERV 5 @ 3346 m ³ /hr			
Average ASHRAE Dust Weight Arrestance	64	%		
ASHRAE Dust Holding Capacity	98	g		



DATE
12-14-2015

TEST SUPERVISOR
M.A.M.

ADMINISTRATIVE APPROVAL

Michael A. Murphy



AIR FILTER TESTING LABORATORIES, INC.

4632 Old LaGrange Road • Buckner, Kentucky 40010

Phone (502) 222-5720 • Fax (502) 222-9881

ASHRAE STANDARD 52.2-2012

REMOVAL EFFICIENCY BY PARTICLE SIZE (0.3 to 10.0 μm ; KCI)

PERFORMANCE CURVES


REPORT NO.
14170

TEST NO.
1

SHEET NO.
2


CLEAN DEVICE

Airflow Rate -vs- Initial Device Resistance



DUST FED -vs- RESISTANCE

Dust Increment - 20 g ASHRAE



DATE
12-14-2015

TEST SUPERVISOR
M.A.M.

ADMINISTRATIVE
APPROVAL

Michael A. Murphy





AIR FILTER TESTING LABORATORIES, INC.

4632 Old LaGrange Road • Buckner, Kentucky 40010


Phone (502) 222-5720 • Fax (502) 222-9881

ASHRAE STANDARD 52.2-2012 - PERFORMANCE CURVES REMOVAL EFFICIENCY BY PARTICLE SIZE (0.3 to 10.0 μm ; KCl)

PERFORMANCE CURVES

DUST FED -vs- ARRESTANCE

Dust Increment - 20 g ASHRAE



REPORT NO.

14170

TEST NO.

1

SHEET NO.

3

DATE

12-14-2015

TEST SUPERVISOR

M.A.M.

ADMINISTRATIVE

APPROVAL

Michael A. Murphy





AIR FILTER TESTING LABORATORIES, INC.

4632 Old LaGrange Road • Buckner, Kentucky 40010

Phone (502) 222-5720 • Fax (502) 222-9881

ASHRAE STANDARD 52.2-2012 - PERFORMANCE CURVES REMOVAL EFFICIENCY BY PARTICLE SIZE (0.3 to 10.0 µm; KCI)

PERFORMANCE CURVES


REPORT NO.
14170

TEST NO.
1

SHEET NO.
4


PARTICLE SIZE -vs- REMOVAL EFFICIENCY

Incremental KCI Particle Size Removal Efficiency



PARTICLE SIZE -vs- REMOVAL EFFICIENCY

Composite Minimum KCI Particle Size Removal Efficiency



DATE
12-14-2015

TEST SUPERVISOR
M.A.M.

ADMINISTRATIVE
APPROVAL

Michael A. Murphy

